



Electric Construction
Tourism Industry and
Trade Limited Co.



Pump Control Systems



We manage water.
You can use it safely.

JOKER PANEL



1. General Product Informations

Joker control panel is a panel that has the opportunity to monitor and control the operating status and error details of the pumps in single pump booster systems. The Panel includes a specially designed mainboard and 4x20 LCD display. It includes General Error / No Water / Phase Error LEDs and Up / Down buttons that allow you to navigate and adjust the menu. Moreover, There are SET/RESET/ ESC buttons as well as switch, pump running and automatic operation warning leds. System parameters can be easily adjusted from the setting menu with the Set / Esc / Up / Down buttons.




Figure 1. BPL-1T Control Panel Outer View




Figure 2. BPL-1T Control Panel Inner View



Specifications

- 1** 16 bit microprocessor based design
- 2** 48 Mhz operating frequency.
- 3** 4x20 Character Blue Screen LCD
- 4** Displaying the date and time information on the screen
- 5** Ability to automatically self-test 2 days a week (real time clock)
- 6** Automatic test solenoid valve output
- 7** Measuring 3 phase voltage values and displaying them on the screen.
- 8** Ability to set voltage protection upper and lower values.
- 9** Ability to monitor pump error conditions from the screen.
- 10** Ability to display pump currents from the screen
- 11** Ability to set pump upper and lower current values
- 12** Automatic calculation of pump current values with recognition mode
- 13** Ability to limit the number of pumps engaged (switchgear) within 1 hour.
- 14** Automatic resetting of current errors.
- 15** Ability to set automatic reset waiting time and number.
- 16** Automatic and manual operation selection.
- 17** Operation as you press the test button in manual operation.
- 18** Protection against dry running by floater or electrode.
- 19** Undercurrent protection against dry running
- 20** Ability to see all error conditions on the screen.
- 21** Notifying error conditions with audible buzzer and relay contact.
- 22** Ability to use with pressure transmitter.
- 23** Ability to see the pressure value on screen when using with pressure transmitter.
- 24** Adjustment of set pressure value when using pressure transmitter.
- 25** Ability to display the pump running times on the screen.
- 26** Real-time co-aging
- 27** PTC (temperature) protection of all pumps.
- 28** Ability to use as a waste water panel (menu option)
- 29** Water leakage connection in the selection of waste water panel.
- 30** Password protection against unauthorized access
- 31** Turkish Usage Menu
- 32** Failure record-The device stores the last 20 faults with date and time.

General Informations

- Electrical panel is designed based on microcontroller.
- All control operations on the electrical panel are performed electronically and stored
- The electronic card in the electrical panel is produced with high technology SMD material.
- SMD LED lamp LCD (liquid Crystal Display) screen with minimum energy consumption is used as an indicator.

Technical Specifications

Operating Voltage	3x380V AC
Running Frequency	50 - 60 Hz.
Running Current	0,02 - 5,5 A.
Screen	4x20 Character Blue Screen LCD
Measurement Accuracy	± %1
Temperature	-20.....+50°C
Dimensions (mm)	200X280X140
Weight	2350 gr.

Figure 3. Technical Specifications
280mm.






Figure 4. Panel Dimensions




Single Pump Hydrophore




Single Pump Waste Water :



Single Pump Hydrophore + Ptc :



Single Pump Waste Water Stop Floater :



In waste water panels, the ground line must be connected to Terminal 20

CERTIFICATE
Attestation of Conformity

Name and Address of Certificate Holder:
KRK ELEKTRİK İNŞ. TURZ. SAN. VE TİC. LTD. ŞTİ.
Esenler Mah. Gözde Sok. No:1 Pendik / İSTANBUL

Certificate Number:
SE-226-03

Name and Address of Manufacturer:
KRK ELEKTRİK İNŞ. TURZ. SAN. VE TİC. LTD. ŞTİ.
Esenler Mah. Gözde Sok. No:1 Pendik / İSTANBUL

Date of Issue:
27-01-2020

Brand:
BLACKSTN

Product Name:
Control Panel

Expiration Date:
27-01-2021

Model No:
BPL-2; BPL-T; BPL-M; BPL-1T; BPL-1M; BPL-2T; BPL-2M;
BPL-3T; BPL-3M; BPL-U1T; BPL-U1M; BPL-U2T; BPL-U2M;
BPL-U3T; BPL-U3M

Test Report Number:
1806.10.03/10
18-1195-R00-N00-00

Page:
1 of 1

Test Required:
EN 61010:2010 & EN 61000-6-1:2007
EN 61000-6-3:2007/A1:2011/AC:2012

The product meets the technical requirement of the above standards and hence fulfills the technical requirements of the following directives.

2014/35/EU Low Voltage Directive
2014/30/EU Electromagnetic Compatibility Directive

This certificate is only valid for the equipment and configuration described, in conjunction with the test data detailed above and with compliance with all applicable legal requirements for the product.

The CE Mark as shown below can be used, under the responsibility of the manufacturer or the importer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives.

SIGNATURE

CE

QR CODE



LVT Test Laboratuvarları Ltd. Şti.

Yenişehir Mah. Çarşı Sok. No: 1/1 Kat: 1/1 Pendik / İstanbul

DENEY RAPORU

Müşteri Adı/Adresi: KRK ELEKTRİK İNŞ. TURZ. SAN. VE TİC. LTD. ŞTİ.
Müşteri Adres: ESENLER MAHALLESİ GÖZDE SOKAKI NO:1 PENDİK / İSTANBUL

Deney No: 1806.10.03/10
Deney Tarihi: 27.01.2020

Deney Standartları: EN 61010:2010 & EN 61000-6-1:2007
Deney Yöntemi: EN 61000-6-3:2007/A1:2011/AC:2012

Deney Sonuçları: OLUMLU / AYRINTILAR AŞAĞIDAKİ SAYFALARDA VERİLMİŞTİR.

Deney Sorumlusu: Mehmet ŞUMNU
Laboratuvar Müdürü: Caner EREN

TEST LABORATUVARLARI

CE

TESILAB
www.testila.com.tr

TESTLA
Elektrik Laboratuvarları Tic. Ltd. Şti.
Kuzuluk Mah. Ankara Cad. No: 34
Akyazı / SAKARYA / TÜRKİYE
Tel: +90 264 437 97 70 Faks: +90 264 437 97 80

TÜRKAK
AB-0386-T
1806.10.03/00
27.07.2018

DENEY RAPORU
TEST REPORT

Müşteri Adı/Adresi: KRK ELEKTRİK İNŞ. TURZ. SAN. VE TİC. LTD. ŞTİ.
Esenler Mahallesi Gözde Sokak No: 1 Pendik / İSTANBUL

Numunenin Adı ve Tanımı: BLACKSTN Marka BPL-2T Tipi Kontrol Panosu

Talep Numarası: 1806.10
Bu talebe bağlı rapor sayısı: 3

Rapor Sayfa Sayısı: 21 + 5 sayfa ek
Toplam 26 sayfa

Deney Standartları: TS EN 61010-1: 05.06.2012 Ölçme, Kontrol Ve Laboratuvarında Kullanılan Elektriksel Donanım İçin Güvenlik Kuralları- Bölüm 1: Genel Kurallar

Deney Sonuçları: OLUMLU / Ayrıntılar aşağıdaki sayfalarda verilmiştir.
POSITIVE Details, are given on the following pages which are part of this report.

Açıklamalar
Remarks

Bu rapor, yalnızca deneyleri yapılan numune-ler için geçerlidir.
The test results relate only to the items tested.

Bu deney raporunda (B) işaretli deneyler, TÜRKAK tan alınmış akreditasyon kapsamında değildir.
Tests marked (B) in this test report are not included in the TÜRKAK accreditation schedule for this laboratory.

Deney laboratuvarı olarak faaliyet gösteren TESTLA Elektrik Laboratuvarları TÜRKAK'tan AB-0386-T ile TS EN ISO/TS EN 17025:2012 standardına göre akredite edilmiştir.
TESTLA Elektrik Laboratuvarları accredited by TÜRKAK under registration number AB-0386-T for TS EN ISO/TS EN 17025:2012 as test laboratory

Türk Akreditasyon Kurumu(TÜRKAK) deney raporlarının tanınırlığı konusunda Avrupa Akreditasyon Birliği(EA) ile Çok Taraflı Anlaşma ve Ulaştırması Laboratuvar Akreditasyon Birliği(LAC) ile karşılıklı tanıma anlaşması imzalamıştır.
Turkish Accreditation Agency (TÜRKAK) is a signatory to the European co-operation for Accreditation (EA) Multilateral Agreement (MLA) and to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA) for the recognition of test reports.

Deney ve veya ölçüm sonuçları, genişletilmiş ölçüm belirsizlikleri (olması halinde) ve deney metotları bu sertifikanın tamamlayıcı kısmı olan takip eden sayfalarda verilmiştir.
The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

Mühür: KRK ELEKTRİK İNŞ. TURZ. SAN. VE TİC. LTD. ŞTİ. TESILAB 2010

Rapor Tarihi: 27.07.2018

Deney Sorumlusu: Mehmet ŞUMNU

Laboratuvar Müdürü: Caner EREN

Bu rapor, laboratuvarımızın yazılı izni olmadan kiemen kopyalanıp çoğaltılamaz. İmzasız raporlar geçersizdir.
This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature is not valid.

Quality Certificates

